



NOTE:

1. FOR LEGEND, ABBREVIATIONS AND GENERAL NOTES, SEE DWG E-1.

CIRCUIT LEGEND:

CIRCUIT DESIGNATION	CIRCUIT NUMBER OR NAME	TYPE OF CIRCUIT
STR - X	A TO G - STROBE AND SPEAKER CIRCUIT NUMBER	STR - STROBE CIRCUIT
	ATC - CIRCUIT TO ADDRESSABLE TERMINAL STRIP CABINET	SPK - SPEAKER CIRCUIT
	PS - CIRCUIT TO PULL STATIONS	ALD - ALD LOOP DEVICE (EXCEPT SMOKE DETECTOR) CIRCUIT
	ELEV - CIRCUIT TO ELEV LOBBY & ELEV MACHINE ROOM SMOKE DETECTORS	SD - SMOKE DETECTOR CIRCUIT
	HVAC - CIRCUIT TO HVAC SMOKE DETECTORS	
	AREA - CIRCUIT TO OPEN AREA SMOKE DETECTORS	

Sheet 8 of 21

**THE PORT AUTHORITY
OF NY & NJ**

Peter K. Surway
ENGINEERING PROGRAM MANAGER
W.T.C.
J. Bullock
CHIEF ELECTRICAL ENGINEER

I HEREBY CERTIFY THAT THIS IS A TRUE AND CORRECT COPY OF ONE OF THE CONTRACT DRAWINGS CONSTITUTING A PART OF CONTRACT NO. IN THE FORM IN WHICH SAID DRAWINGS EXISTED AT THE TIME THE SAID CONTRACT WAS EXECUTED BY THE PARTIES.

DATE 7-15-97 *Surway* SPEC. WRITER
DATE 7-18-97 *Bullock* ENGINEER OF DESIGN

No. Date Revision Approved

Engineering Department
Design Divisions

**The World Trade
Center**

Title
**FIRE ALARM SYSTEM
DEVICE UPGRADE
PHASE III**
ELECTRICAL
**1 WTC
66th FLOOR
RISER DIAGRAM**

This drawing subject to conditions in contract. All inventions, ideas, designs and methods herein are reserved to Port Authority and may not be used without its written consent.

S. FELDSTEIN B. FALDU *Jim*
Designed by Drawn by Checked by

Date 2/4/97 Scale NONE

Contract Number Drawing Number

WTC-861.077 E-7